



Attestation of Conformity

No. N8A 115676 0009 Rev. 02

Holder of Attestation: **Solar Fabrik GmbH**
Hermann-Niggemann-Str. 7-9
63846 Laufach
GERMANY

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062576301-02

Date, 2026-08-14

(Zhulin Zhang)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Attestation of Conformity

No. N8A 115676 0009 Rev. 02

Model(s):

S4-DGxxx-144P-BC-W (xxx=585-655, in step of 5)
 S4-DGxxx-108BC-W (xxx=455-500, in step of 5)
 S4-DGxxx-120BC-W (xxx=520-555, in step of 5)
 S4-DGxxx-144BC-W (xxx=610-670, in step of 5)
 S4-DGxxx-108BC-FB (xxx=460-495, in step of 5)
 S4-DGxxx-144BC-FB (xxx=625-655, in step of 5)
 S4-DGxxx-64BC-HJT-W (xxx=280-310, in step of 5)
 S4-DGxxx-72BC-HJT-W (xxx=320-350, in step of 5)
 S4-DGxxx-96BC-HJT-W (xxx=430-460, in step of 5)
 S4-DGxxx-108BC-HJT-W (xxx=485-515, in step of 5)
 S4-DGxxx-120BC-HJT-W (xxx=540-570, in step of 5)
 S4-DGxxx-132BC-HJT-W (xxx=595-625, in step of 5)
 S4-DGxxx-144BC-HJT-W (xxx=650-690, in step of 5)
 S4-DGxxx-64BC-HJT-FB (xxx=280-310, in step of 5)
 S4-DGxxx-72BC-HJT-FB (xxx=315-345, in step of 5)
 S4-DGxxx-96BC-HJT-FB (xxx=425-455, in step of 5)
 S4-DGxxx-108BC-HJT-FB (xxx=480-510, in step of 5)
 S4-DGxxx-120BC-HJT-FB (xxx=535-565, in step of 5)
 S4-DGxxx-132BC-HJT-FB (xxx=590-620, in step of 5)
 S4-DGxxx-144BC-HJT-FB (xxx=650-680, in step of 5)
 S4-DGxxx-132BC-W (xxx=600-670, in step of 5)
 S4-DGxxx-108BC-B (xxx=455-500, in step of 5)
 S4-DGxxx-120BC-B (xxx=520-555, in step of 5)
 S4-DGxxx-132BC-B (xxx=600-670, in step of 5)
 S4-DGxxx-144BC-B (xxx=610-670, in step of 5)
 S5-DGxxx-64BC-FB (xxx=260-295, in step of 5)
 xxx stands for rated output power at STC.

Parameters:

Fire Safety Class:	Class A or C according to UL790.
Safety Class:	Class II
Max. system voltage:	1500V DC
Construction:	Framed or Frameless, with Junction box, cable and connector.

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.